


Installation and Service Instructions

for use by heating contractor

VIESSMANN[®]

BMS communication with heating systems via Modbus
WAGO MB/TCP GATEWAY
WAGO MB/RTU GATEWAY

WAGO MB/TCP GATEWAY **WAGO MB/RTU GATEWAY**



Product may not be exactly as shown

IMPORTANT

Read and save these instructions for future reference.

Safety, Installation and Warranty Requirements

Please ensure that these instructions are read and understood before commencing installation. Failure to comply with the instructions listed below and details printed in this manual can cause product/property damage, severe personal injury, and/or loss of life. Ensure all requirements below are understood and fulfilled (including detailed information found in manual subsections).

■ Product documentation

Read all applicable documentation before commencing installation. Store documentation near boiler in a readily accessible location for reference in the future by service personnel.

► *For a listing of applicable literature, please see section entitled "Important Regulatory and Safety Requirements".*



■ Warranty

Information contained in this and related product documentation must be read and followed. Failure to do so renders the warranty null and void.



■ Licensed professional heating contractor

The installation, adjustment, service and maintenance of this equipment must be performed by a licensed professional heating contractor.

► *Please see section entitled Safety and "Important Regulatory and Installation Requirements".*



■ Advice to owner

Once the installation work is complete, the heating contractor must familiarize the system operator/ultimate owner with all equipment, as well as safety precautions/requirements, shutdown procedure, and the need for professional service annually before the heating season begins.

	Page
Safety	Safety, Installation and Warranty Requirements2
	Product documentation2
	Licensed professional heating contractor2
	Advice to owner2
	Warranty.....2
General Information	Important Regulatory and Installation Requirements 4
	Approvals.....4
	Codes.....4
	Working on the equipment.....4
	Power supply4
	About these Installation Instructions4
Installation	Intended Use 5
	Product Information5
	Spare Parts Lists5
	Mounting the Gateway6
	Preparing for Installation7
	Process Overview8
	Installing the Module8
	Connections and Operating Elements9
	Connecting and Releasing Cores12
	Establishing the CAN Bus Connection13
	Connecting the Plug-in Attachment15
	Establishing the Connections to the Modbus/TCP or Modbus/RTU16
	Connecting the Gateway to the Power Supply Unit16
	Power Supply17
	Commissioning the Gateway18
	Dismounting the Power Supply Unit18
	Dismounting the Gateway19
Specifications	Gateway20
	Power Supply22
Additional Information	Final Decommissioning and Disposal23

Important Regulatory and Installation Requirements

Approvals

Viessmann boilers, burners and controls are approved for sale in North America by CSA International.

Codes

The installation of this unit shall be in accordance with local codes. In the absence of local codes, use:

- CSA C22.1 Part 1 and/or local codes in Canada
- National Electrical Code ANSI/NFPA 70 in the U.S.

Always use latest editions of codes.

The heating contractor must comply with the Standard for Controls and Safety Devices for Automatically Fired Boilers, ANSI/ASME CSD-1 where required by the authority having jurisdiction.

Working on the equipment

The installation, adjustment, service, and maintenance of this product must be done by a licensed professional heating contractor who is qualified and experienced in the installation, service, and maintenance of hot water boilers. There are no user serviceable parts on the boiler, burner, or control.

Power supply

Install power supply in accordance with the regulations of the authorities having jurisdiction or, in absence of such requirements, in accordance with National Codes. Viessmann recommends the installation of a disconnect switch to the 120V power supply outside of the boiler room.

Ensure main power supply to equipment, the heating system, and all external controls have been deactivated. Close main oil or gas supply valve. Take precautions in both instances to avoid accidental activation of power during service work.

- ▶ Please carefully read this manual prior to attempting installation. Any warranty is null and void if these instructions are not followed.

For information regarding other Viessmann System Technology componentry, please reference documentation of the respective product.

We offer frequent installation and service seminars to familiarize our partners with our products. Please inquire.

- ▶ The completeness and functionality of field supplied electrical controls and components must be verified by the heating contractor. These include low water cut-offs, flow switches (if used), staging controls, pumps, motorized valves, air vents, thermostats, etc.


	<p>! WARNING</p> <p>Turn off electric power supply before servicing. Contact with live electric components can cause shock or loss of life.</p>
------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------

About these Installation Instructions

- ! Take note of all symbols and notations intended to draw attention to potential hazards or important product information.**

 <p>WARNING</p>
<p>Warnings draw your attention to the presence of potential hazards or important product information.</p>

- ▶ Indicates an imminently hazardous situation which, if not avoided, could result in death, serious injury or substantial product/property damage.

 <p>CAUTION</p>
<p>Cautions draw your attention to the presence of potential hazards or important product information.</p>

- ▶ Indicates an imminently hazardous situation which, if not avoided, may result in minor injury or product / property damage.

<p>IMPORTANT</p>

- ▶ Helpful hints for installation, operation or maintenance which pertain to the product.



- ▶ This symbol indicates to note additional information
- ▶ This symbol indicates that other instructions must be referenced.

Intended Use

Intended use

The gateway is only intended to be installed and operated in conjunction with Viessmann control units, with due attention paid to the associated installation, service and operating instructions. The gateway may only be used in systems with supported Viessmann heat and power generators.

The gateway can only be used with the user and communication interfaces defined in the product documentation for the following purposes:

- To monitor systems
- To operate systems
- To optimize systems

With regard to the communication interfaces, ensure on site that the system requirements specified in the product documentation are met at all times for every transfer medium employed. Only use the specified components for the power supply (e.g. power supply units). Intended use presupposes that a fixed installation in conjunction with permissible, system-specific components has been carried out.

Commercial or industrial use for a purpose other than the monitoring, operation and optimization of supported, approved systems shall be deemed inappropriate. Incorrect usage or operation of the appliance (e.g. the appliance being opened by the system user) is prohibited and will result in an exclusion of liability. Incorrect usage also occurs if the components in the Viessmann system are modified from their intended function.

Product Information

The WAGO MB/TCP gateway and the WAGO MB/RTU gateway are used to connect Viessmann control units to Modbus systems. For supported devices and other valid product documentation, see; www.automationgateway.info

Functions


The gateway enables system users to utilise the following functions in conjunction with a Modbus system:

- Transferring heating system operating states
- Setting heating system parameters
- Relaying fault and maintenance messages


Spare Parts Lists

Information about spare parts can be found at www.viessmann.com/etapp or in the Viessmann spare part app.

Mounting the Gateway




1. Loosen the retaining screws from the extension kit enclosure (do not remove).
2. Remove cover and set aside.




3. Mount the extension module enclosure to the wall using the appropriate hardware.

Preparing for Installation

WAGO MB/TCP gateway system overview



WAGO MB/RTU gateway system overview



Legend

- (A) Viessmann boiler
- (B) Building management system
- (C) Terminator 120 Ω
- (D) Gateway
- (E) Power supply unit
- (F) Laptop with web browser and WAGO Web-Visu
- (G) Module enclosure

Process Overview

Step		Responsibility	Page
1	Establish the CAN bus connection.	Contractor	13
2	Connect the plug-in attachment.	Contractor	15
3	Establish the connection to the Modbus.	IT expert/system integrator	16
4	Power supply	Electrician	17
5	Commission the gateway.	IT expert/system integrator	18

Installing the Module

IMPORTANT

Incorrect ambient conditions and installation locations may impair data transfer and cause damage to the gateway.

Ambient conditions during operation

- Permissible ambient temperature: 32 to 104°F (0 to 40°C)
- Permissible relative humidity:
 - 32 to 104°F (0 to 39°C): ≤ 95%
 - ≥ 104°F (≥ 40°C): ≤ 50%
- No direct sunlight

IMPORTANT


Operation by unauthorized persons may result in damage to the system. Access to the gateway must only be possible for authorized specialists.

Overview of connecting cables

Connecting cables	Length
Accessories: CAN bus cable	23 ft. (7 m)

Connections and Operating Elements

WAGO MB/TCP gateway




Legend

- (B) LED status indicators
- (C) Reset button RST
- (D) Status LED for supply voltage
- (E) Status LED for CAN bus interface
- (F) Plug-in attachment with terminator: See page 16
- (G) CAN low, for looping through the CAN bus
- (H) CAN high, for looping through the CAN bus
- (K) CAN bus shield
- (L) 24VDC supply voltage connection
- (M) Do not open!
- (N) Operating mode switch
 RUN Standard mode
 Factory setting: Do not adjust!
 STOP Only for update process; see WAGO commissioning manual.
 RESET Do not adjust!
- (O) Service interface: LAN connection to PC/laptop or Modbus/TCP connection
- (P) Memory card slot

Connections and Operating Elements *(continued)*

WAGO MB/RTU gateway




Legend

- (A) Connection for PROFIBUS field bus plug for Mod-bus / RTU building management system
- (B) LED status indicators
- (C) Reset button RST
- (D) Status LED for supply voltage
- (E) Status LED for CAN bus interface
- (F) Status LED for Modbus/RTU interface
- (G) Plug-in attachment with terminator: See page 16
- (H) CAN high, for looping through the CAN bus
- (K) CAN low, for looping through the CAN bus
- (P) Earth
- (Q) Modbus shield
- (R) CAN bus shield
- (S) 24VDC supply voltage connection
- (T) Do not open!
- (U) Operating mode switch
 RUN Standard mode
 Factory setting: Do not adjust!
 STOP Do not adjust!
 RESET Do not adjust!
- (V) Service interface: LAN port for connection to PC/laptop
- (W) Memory card slot

Connections and Operating Elements *(continued)*

Installing the PROFIBUS connector




Legend

- Ⓐ PROFIBUS connector
- Ⓑ WAGO MB/RTU Gateway

LED indicators

LED	Status	Meaning	Measure
User LED UI	Green	The connection to the boiler is active.	--
	Red	The CAN bus interface has the status "Bus Off": Short circuit or other serious fault	<ul style="list-style-type: none"> ■ Check CAN bus connection: Plug, cable, terminator ■ Check whether boiler is switched on. ■ Check installation and connections of gateway and power supply unit. ■ Check address selector. If necessary, restore the factory settings as shown in the diagram on page 10. ■ If the fault cannot be rectified, contact Viessmann Technical Service.
	Other	Fault	Contact Viessmann Technical Service.

Power supply unit




Legend

- Ⓐ INPUT 120VAC 60 Hz
- Ⓑ OUTPUT 24VDC, 1.3A


Connecting and Releasing Cores

WAGO MB/TCP gateway



1. Insert a small flat head screwdriver into the opening directly above the wire..
2. Tilt the handle of the screwdriver up.
3. Pull the wire straight out.

Power supply unit



1. Using a small screwdriver push in the orange button directly above the wire.
2. Pull the wire straight out.

Establishing the CAN Bus Connection

- The Viessmann CAN bus is designed for “line” bus topology with a terminator at both ends (accessories).
- With CAN bus, the transmission quality and the cable lengths depend on the electrical properties of the cable:
 - Only use cable types listed in the following table.
 - Only use one cable type within a CAN bus.

Recommended cable type (on site):


CAN bus cable	In line with ISO 11898-2, twisted pair cable, shielded
■ Cable cross-section	0.34 to 0.6 mm ² (22 to 18 AWG)
■ Characteristic impedance	95 to 140 Ω
■ Max. length	650 ft. (200 m)

Alternative cable types (on site):

CAN bus cable	2-core, CAT5, shielded
■ Max. length	165 ft. (50 m)
CAN bus cable	2-core, CAT7, shielded
■ Max. length	650 ft. (200 m)


Establishing the CAN Bus Connection *(continued)*

WAGO MB/TCP gateway




Legend

- Ⓐ CAN bus shield
- Ⓑ Cable for 91 for controlling the boiler (standard delivery of the gateway)

 Installation and service instructions for boiler control unit

Connecting the Plug-in Attachment



WAGO MB/TCP/RTU gateway


The plug-in attachment (pre-installed) must be plugged in.

Do not connect the plug-in attachment until the CAN bus cable has been connected.

If the gateway is at the beginning or end of the CAN bus:

Legend

Ⓐ Plug-in attachment with terminator (standard delivery)



If the gateway is not at the beginning or end of the CAN bus:

Plug in the plug-in attachment without the terminator. Use the plug-in attachment for looping through the CAN bus.

Legend

Ⓐ Plug-in attachment (standard delivery)


Ⓑ Terminator

Establishing the Connection to the Modbus/TCP or Modbus/RTU

The connection to the required network must be established by the system integrator.

Note: For the Modbus/RTU connection, see description of the PROFIBUS fieldbus plug.

Connecting the Gateway to the Power Supply Unit



Legend

Ⓐ Cable cores between gateway and power supply unit (standard delivery)

The WAGO gateway is supplied in the enclosure with the power supply unit prewired to the gateway.

Power Supply

General information

The WAGO gateway comes complete with a 6 ft. (2 m) power cord with convenience plug for simplified installation.



WARNING

The control must be grounded.
Ensure that 'L', 'N' and 'G' are not interchanged.




WARNING

Incorrectly executed electrical installations can lead to injuries from electrical current and result in appliance damage.

IMPORTANT

Electrical installations must comply with the latest edition of:

- In the U.S.A., the National Electrical Code (NEC), ANSI/NFPA 70 and any other state, local codes and/or regulations.
- In Canada, the Canadian Electrical Code (CEC), CSA C22.1 Part 1 and any other province, territory, local codes and/or regulations.



Commissioning the Gateway

Commissioning must be carried out by the IT expert or system integrator.


1. Switch on the boiler.
2. Switch on the power supply for the gateway.
3. Check the status of the LED for standard mode after switching on: See the following table. If the LED indicators do not match the table, check the connections: See overview on page 8.

LED indicators	Status of the LED for standard mode
SYS	Green
RUN	Green
I/O	Green
MS	OFF
NS	OFF
UI	Green
U2-U7	OFF

4. For further commissioning steps, see the “WAGO Modbus automation gateway commissioning manual” at www.automation-gateway.info


Dismounting the Power Supply Unit

If the gateway or power supply unit need to be removed, e.g. because the device is faulty, proceed as shown in the following diagrams.




Dismounting the Gateway

Dismounting the terminals



If the gateway or power supply unit need to be removed, e.g. because the device is faulty, proceed as shown in the following diagrams.

Dismounting the controller



Gateway


WAGO MB/TCP gateway

Power supply	24VDC
Power consumption	Max. 116 mA
Rated power	2.8 W
Permissible ambient temperature <ul style="list-style-type: none"> ■ Operation ■ Storage ■ Transport 	32 to 104°F (0 to 40°C) -4 to 140°F (-20 to +60°C) -4 to 140°F (-20 to +60°C) for max. 3 months or average 95°F (35°C)
Dimensions	<p>4 in. (100 mm)</p> <p>4 in. (100 mm)</p> <p>2 1/2 in. (65 mm)</p> <p>3 in. (72 mm)</p>

Gateway *(continued)*

WAGO MB/RTU gateway	
Power supply	24VDC
Power consumption	Max. 141 mA
Rated power	3.4 W
Permissible ambient temperature <ul style="list-style-type: none"> ■ Operation ■ Storage ■ Transport 	32 to 104°F (0 to 40°C) -4 to 140°F (-20 to +60°C) -4 to 140°F (-20 to +60°C) for max. 3 months or average 95°F (35°C)
Dimensions	<p>The diagram shows an isometric view of the WAGO MB/RTU gateway. It is a rectangular metal enclosure with a front door. On the left side of the front panel, there are two RJ45 ports. On the right side, there are several terminal blocks for wiring. The dimensions are indicated as follows: <ul style="list-style-type: none"> Height: 4 in. (100 mm) Depth: 4 in. (100 mm) Width (from the left side): 2 1/2 in. (65 mm) Width (from the right side): 3 in. (72 mm) </p>

Power Supply


Power supply unit	
Rated voltage	100 to 240V ~
Rated frequency	50 to 60 Hz
Rated current	1.34A
Output voltage	24VDC
Permissible ambient temperature	
■ Operation	32 to 104°F (0 to +40°C)
■ Storage and transport	-40 to +185°F (-40 to +85°C)
Dimensions	 <p>Isometric drawing of the power supply unit showing dimensions:</p> <ul style="list-style-type: none"> Top width: 2 1/4 in. (54 mm) Height: 3 1/2 in. (90 mm) Front width: 2 in. (52.5 mm) Depth: 2 1/4 in. (56 mm)

Final Decommissioning and Disposal

Viessmann products can be recycled. Components and substances from the system are not part of ordinary household waste.

For decommissioning the system, isolate the system from the power supply and allow components to cool down where appropriate.

All components must be disposed of correctly.



Printed on environmentally friendly (recycled and recyclable) paper.

Technical information subject to change without notice.

5472 800 - 02

Scan for digital copy of this document



Viessmann Manufacturing Company Inc.
 750 McMurray Road
 Waterloo, Ontario • N2V 2G5 • Canada
TechInfo Line 1-888-484-8643
 1-800-387-7373 • Fax (519) 885-0887
www.viessmann.ca • info@viessmann.ca

Viessmann Manufacturing Company (U.S.) Inc.
 45 Access Road
 Warwick, Rhode Island • 02886 • USA
TechInfo Line 1-844-649-5886
 1-800-288-0667 • Fax (401) 732-0590
www.viessmann-us.com • info@viessmann-us.com